



Prokuplje, Dragoljuba Rakića 7a  
 +381 27 321 177; +381 27 334 310  
 Tekući račun: 325-950080000702-77

[kontakt@abmelektro.com](mailto:kontakt@abmelektro.com)  
[www.abmelektro.com](http://www.abmelektro.com)  
 PIB: 100 415 391



**RADE KONČAR** KONTAKTORI I RELEI D.O.O.



#### KONDENZATORSKE BATERIJE

OSNOVNE KARAKTERISTIKE	TIP	RSD
1,0 kVari, 440V/50Hz	RKC 440 S, 1,0 kVari	1873
2,5 kVari, 440V/50Hz	RKC 440 S, 2,5 kVari	2590
5,0 kVari, 440V/50Hz	RKC 440 S, 5 kVari	3006
7,5 kVari, 440V/50Hz	RKC 440 S, 7,5 kVari	4278
10,0 kVari, 440V/50Hz	RKC 440 S, 10 kVari	4625
12,5 kVari, 440V/50Hz	RKC 440 S, 12,5 kVari	5296
15,0 kVari, 440V/50Hz	RKC 440 S, 15 kVari	6359
20,0 kVari, 440V/50Hz	RKC 440 S, 20 kVari	7284
25,0 kVari, 440V/50Hz	RKC 440 S, 25 kVari	8302
30,0 kVari, 440V/50Hz	RKC 440 S, 30 kVari	10291

#### REGULATORI

OSNOVNE KARAKTERISTIKE	TIP	RSD
4-stepeni (jednofazni)	RKPFK 4	11531
6-stepeni (jednofazni)	RKPFK 6	14916
12-stepeni (jednofazni)	RKPFK 12	18642
15-stepeni (trofazni)	RKPFK 15	23312

#### PRIGUŠNICE

OSNOVNE KARAKTERISTIKE	TIP	RSD
12.5 kVAr/400V 189Hz p=7% (15kVAr/440V)	ERH-7/400/12.5	22806
22.2 kVAr/400V 189Hz p=7% (25kVAr/440V)	ERH-7/400/22.2	33056
44.4 kVAr/400V 189Hz p=7% (50kVAr/440V)	ERH-7/400/44.4	45356